

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

### Certificate of constancy of performance 2831-CPR-F4883

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

#### FA100 Single (Expandable to Two) Pipe Aspirating Smoke Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

**INIM ELECTRONICS s.r.l.**  
Via Dei Lavoratori 10  
Frazione Centobuchi  
63076 Montepandone (AP)  
Italy

**INIM ELECTRONICS s.r.l.**  
Via Dei Lavoratori 10  
Frazione Centobuchi  
63076 Montepandone (AP)  
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### EN 54-20:2006 Aspirating Smoke Detector EN 54-17:2005 Short Circuit Isolator

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

#### **the constancy of performance of the construction product.**

This certificate was first issued on 10 May 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Technical Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 10 May 2024

Issue Date: 10 May 2024

Issue Number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland**

**Approved Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F4883****FA100 Single (Expandable to Two) Pipe Aspirating Smoke Detector with Short Circuit Isolator**

## Notes:

1. For compliance with Clause 5.10 of EN 54-20:2006, the detector shall be supplied with power from a power supply complying with EN 54-4.

2. The approval of the detector is conditional upon the following requirements:

- Design, installation, and commissioning are performed in accordance with the Installation and programming manual (DCMIINE0FA100-100)


3. The FA100 detector is approved for the following classes and sensitivities:

- Class A: 0.00235-0.025 dB/m
- Class B: 0.00235-0.060 dB/m
- Class C: 0.00235-0.200 dB/m

The Class of any pipework and hole configuration, detector sensitivity and equipment parameters must be determined using FA/STUDIO software.

4. The aspirating detector is approved with the following ancillary components:

- FAD100 - Detector module
- FAD100Filter - Metal mesh with gasket
- 504F075ABS - Dust filter (Medium F0.75 filter with RL5 cartridge ABS)
- WT025 - Condensate trap ABS
- 2510025 - 3-way ball valve PVC / EPDM
- 1725001950 - Flexible transparent spiral pipe p-PVC with carbon steel wire (External Ø: 25mm)
- AAD12025CRS - Male / Female fitting (for the dust filter) ABS
- TUBOABS0250M - Pipe
- SASO100250RS - Coupling sleeve
- SATE400250RS - T-piece

  
P Halligan, Technical Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 10 May 2024

Issue Date: 10 May 2024

Issue Number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)


**BRE Global Ireland**

**Approved Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F4883**

**FA100 Single (Expandable to Two) Pipe Aspirating Smoke Detector with Short Circuit Isolator**

- SABE300250RS - 90° bend
- SAEY500250RS - 45° Elbow
- SACA700250RS - Pipe end cap
- SAUN800250RS - Openable joint sleeve
- STS25REDK - Hose clip
- SGLUEN0250 - Sealing glue
- SGLUEN0500 - Sealing glue
- MPE1008025M-R - Red flexible pipe for sampling capillaries
- LABEL23X10 - Sampling hole identification labels with written "ASPIRATING POINT"
- CAPKIT2510SR - Kit for the creation of a sampling capillary

  
P Halligan, Technical Manager  
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 10 May 2024  
Issue Date: 10 May 2024  
Issue Number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)