

## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 14A, Srebarna Str.  
1407 Sofia, Bulgaria

**Declares that the**

**Product:** MAG8 Plus  
MAG4Plus  
Fire Line MAG8 Plus  
Fire Line MAG4 Plus  
AE/C5-8-16

**Description:** Conventional Fire Alarm Control Panel

**Complies to the following standards:**

EN 54-2: 1997/A1: 2006  
EN 54-4: 1997/A2: 2006  
EN 60950-1: 2006/ A11: 2009 + A12 :2011 + A1 :2010 + A2 :2013  
EN 55032: 2015  
EN 61000-3-2: 2006/A1: 2009 + A2: 2009  
EN 61000-3-3: 2008

**The following Regulation:**

CPR № 305/2011  
REACH No 1907/2006

**And the following Directives:**

2014/30/EC- EMC  
2011/65/EU – RoHSII

**Additional information:**

**First date of production:** 02.2006

**Certificate:**

№ 1293 – CPR–0546 of April 13, 2010 from Notified body № 1293 EVPU  
№ 00132/101/1/2010 of May 31, 2010 from Notified body № 1293 EVPU

**Test report:**

№ 00258/2010/C of May 31, 2010 from Notified body № 1293 EVPU

1407 Sofia,  
14A, Srebarna Str.  
13.04.2017

Yuliy Iliev  
Quality Manager

