



EVPU[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0832

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Addressable manual call point P700N

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Notifier Italia S.r.l.

Via Grandi, 22, 20097 San Donato Milanese (MI), Italy

and produced in the manufacturing plant

IT 00942050287

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11: 2001

EN 54-11: 2001/A1: 2005

EN 54-17: 2005

EN 54-17: 2005/AC: 2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on April 14th, 2022 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, April 14th, 2022

Michal Mišiak

054265

Annex to Certificate No. 1293 - CPR – 0832 from April 14th, 2022

Technical specifications:

P700N addressable break-glass call point is designed to be use as a manual fire alarm stations in a fire alarm system. P700N is equipped with a rotaryswitch for addressing and a jumper to override the isolator function. The button can operate in either CLIP or Advanced ADV protocol.

Products parameters:

Maximum call point for each loop:	159 in protocol ADV or 99 in CLIP
Voltage range:	15-30 Vdc
Normal voltage:	24 Vdc
Weight:	213 gr
Color:	Red

Essential characteristics	Harmonised technical specification		Performance
	EN 54-11:2001 EN 54-11/A1:2005	EN 54-17:2005 EN 54-17/AC:2007	
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	cl. 5.2	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8=N/A, 5.9	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11=N/A, 5.12, 5.19=N/A	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11=N/A, 5.13	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	cl. 5.3, 5.13	Pass



Nová Dubnica, April 14th, 2022

Michal Mišíak