



EVPU[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0472 Rev.1

In compliance with the *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Intelligent analogue addressable fire alarm monitored output module for conventional sounders with built-in isolator module SensolRIS MOUT, Belinda MOUT, Erida MOUT, Marl MOUT, Smoke sense MOUT, SensolRIS MOUT IP55, Expera SCi IP55, MAGPRO-10SiM

For specifications see Annex to this certificate placed on the market under the name or trade mark of

Teletek Electronics JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-18:2005

EN 54-18:2005/AC:2007

EN 54-17:2005

EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on October 28th, 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, October 28th, 2020

053742




Marek Hudák
Director NB

Annex to Certificate No. 1293 - CPR – 0472 Rev.1 from October 28th, 2020

Technical Specifications

SensolRIS MOUT (derived variants Belinda MOUT, Erida MOUT, Marl MOUT, Smoke sense MOUT, SensolRIS MOUT IP55, Expera Sci IP55, MAGPRO-10SiIM) is an addressable module with one potential output designed for application in addressable fire alarm systems, supporting TTE communication protocol. The module provides interface between a zone of conventional sounders and IRIS and SIMPO addressable fire panels. The module has a built-in isolator module which when used allows continuous operation of the loop in case of module's failure and without need of using additional isolator modules.

The modules SensolRIS MOUT, Belinda MOUT, Erida MOUT, Marl MOUT, Smoke sense MOUT are mounted in a separate small plastic box suitable for wall mounting, with transparent cover for visual inspection.

The modules SensolRIS MOUT IP55, Expera Sci IP55, MAGPRO-10SiIM are mounted in a separate plastic box suitable for wall mounting and with IP55 protection.

The device works with Operating voltage (16 – 32) VDC

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005 EN 54-18:2005/ AC:2007	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Response delay (response time)	cl. 5.2	---	Pass
Performance under fire conditions	cl. 5.1.4	cl. 5.2	Pass
Operational reliability	cl. 5.1.4	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.3, 5.4	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	cl. 5.3, 5.13	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0472	Original certificate issued	February 20 th , 2015
2	1293-CPR-0472 Rev.1	Added new models with IP55 Revision of Technical specifications	October 28 th , 2020

Nová Dubnica, October 28th, 2020

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 2 / 2 FCO 425-13 Rev.1

Marek Hudák
Director NB