



# EVPÜ<sup>®</sup>

NOTIFIED BODY No. 1293

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0454

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Intelligent analogue addressable fire alarm heat detector  
SensolRIS T110, MAGPRO-HD1, Belinda T110, Erida T110,  
Marl T110, Smoke sense T110**

*For specifications see Annex*

produced by

**Teletek Electronics JSC  
14A Srebarňa Str., 1407 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC  
14A Srebarňa Str., 1407 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 54-5: 2000/A1: 2002**

under system 1 are applied and that

**the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on January 30, 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Nová Dubnica, January 30, 2015



The

Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

049873

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, [www.evpu.sk](http://www.evpu.sk)  
Page 1/2 FCO 425-13



**Mařek Huďák**  
Director NB

## Annex to Certificate No. 1293 - CPR - 0454 from January 30, 2015

### General Information:

SensoIRIS T110, MAGPRO-HD1, Belinda T110, Erida T110, Marl T110, Smoke sense T110 is an addressable heat detectors designed for installing in addressable fire alarm systems supporting TTE communication protocol. The detectors is powered on from the panel and can be controlled via the communication protocol. The detectors is compatible with fire base B124.

### Technical specifications:

Operating voltage range	15-32V DC (Nom. 27V DC)
Consumption in quiescent state, no communication	< 130 $\mu$ A@ 27V DC
Consumption in quiescent state, with communication	< 180 $\mu$ A@ 27V DC
Consumption in alarm state, with communication	6.5mA
Class, selectable from the control panel	A1/R, A2/S, B/S

### Products parameters:

Essential characteristics	Performance	Harmonised technical specification
		EN 54-5:2000+A1:2002
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	cl. 4.2, 4.3, 5.2 to 5.6, 5.8, 6.1, 6.2
Tolerance to supply voltage	Pass	cl. 5.7
Operational reliability	Pass	cl. 4.4, 4.6 to 4.11
Durability of operational reliability and response delay: temperature resistance	Pass	cl. 5.9
Durability of operational reliability: humidity resistance	Pass	cl. 5.11, 5.12
Durability of operational reliability: vibration resistance	Pass	cl. 5.14 to 5.17
Durability of operational reliability: corrosion resistance	Pass	cl. 5.13
Durability of operational reliability: electrical stability	Pass	cl. 5.18

Nová Dubnica, January 30, 2015



  
 Marek Hudák  
 Director NB