

## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 2, Iliyansko shose Str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria

**Declares that the**

**Product:** SensoIRIS WS IS  
**Description:** Intelligent analogue addressable fire alarm wall sounder with built-in isolator module

**Complies to the following standards:**

EN 55032:2015  
EN 50130-4:2011; EN 50130-4:2011/A1:2014  
EN 54-3:2001  
EN 54-3:2001/A1:2002  
EN 54-3:2001/A2:2006  
EN 54-17:2005; EN 54-17:2005/AC:2007

**The following Regulation:**

CPR № 305/2011  
REACH No 1907/2006

**And the following Directives:**

2014/30/EU – EMC  
2011/65/EU – RoHS II

**Additional information:**

**First date of production:** 11.2013

**Certificate:**

№1293–CPR- 0705 Rev.1 of November 6<sup>th</sup>, 2023 from Notified body № 1293 EVPU


**Test report:**

№ 9-0045/20 of October 19,2020 from Notified body № 1293 EVPU

**Note:** Sounder SensoIRIS WS IS is compatible with fire bases SensoIRIS B124 and SensoIRIS WSB IP65.

2, Iliyansko shose Str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria  
13.12.2023

Yuliy Iliev  
Quality Manager



1293