



EVPU®

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0462 Rev.3

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of March 9th, 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Intelligent analogue addressable fire alarm sounder and strobe with built-in isolator module SensolRIS WSST IS, MAGPRO -WSS23iM, Belinda WSST IS, Erida WSST IS, Marl WSST IS, Smoke sense WSST IS, Expera WSBWi

For specifications see Annex No. 1, No. 2 and No. 3 to this certificate

placed on the market under the name or trade mark of

**Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-3: 2001, EN 54-3: 2001/A1:2002, EN 54-3:2001/A2: 2006,
EN 54-17: 2005, EN 54-17:2005/AC: 2007, EN 54-23: 2010**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on July 19th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, July 19th, 2024



Michal Mišiak
Head of CB NB No. 1293

056161

Annex No. 1 to Certificate No. 1293 - CPR – 0462 Rev.3 from July 19th, 2024

Technical specifications

Product Intelligent analogue addressable fire alarm sounder and strobe with built-in isolator module SensolRIS WSST IS (derived variants MAGPRO-WSS23iM, Belinda WSST IS, Erida WSST IS, Marl WSST IS, Smoke sense WSST IS, Expera WSBWi) is an addressable wall mounted sounder and strobe with built-in isolator module designed for installing in addressable fire alarm system supporting TTE communication protocol. The device is powered on from the panel and can be controlled via communication protocol.

The sounder is compatible for mounting on the following bases:

1. SensolRIS B124 – standard low-profile base for addressable detectors and sounders
2. SensolRIS B124-HP – standard high-profile base for addressable detectors and sounders
3. WSB IP65 – for wall mounting in harsh environmental conditions

*The device Expera WSBWi is compatible with fire bases Expera SB for ceiling mounting and Expera WP SBB for wall mounting.

Products parameters (Part 1)

Operating Voltage Range	15 - 32VDC (Nom. 27VDC)
Nominal consumption (stand-by)	<500 μ A@27VDC
Maximal consumption (main tone type 27)	
- low volume level, sound only	<5mA
- low volume level, sound and strobe	<12mA
- high volume level, sound only	<16.5mA
- high volume level, sound and strobe	<22mA
Maximal consumption (other tone types)	
- low volume level, sound only	<4mA
- low volume level, sound and strobe	<11mA
- high volume level, sound only	<10mA
- high volume level, sound and strobe	<16.5mA
Consumption with activated isolator	<15mA
Power volume (main tone type 27)	
- low volume	~ 80dB (A) \pm 6dB @ 1m
- high volume	~ 92dB (A) \pm 5dB @ 1m
Power volume (other tone types)	
- low volume	75-85dB \pm 3dB @ 1m
- high volume	80-95dB \pm 3dB @ 1m
Tone type specification	
Tone type 1	970 Hz
Tone type 2	800Hz/970Hz@2Hz
Tone type 3	800Hz - 970Hz@ 1Hz
Tone type 4	970Hz 1s OFF/1s ON
Tone type 5	970Hz 0,5s / 630 Hz, 0.5 s
Tone type 6	554 Hz, 0.1s /440 Hz, 0.4 s (AFNOR NF S 32 001)
Tone type 7	500 – 1200 Hz, 3.5s / 0.5s OFF (NEN 2575:2000)
Tone type 8	420 Hz 0.625s ON/0.625 OFF (Australia AS1670 Alert tone)
Tone type 9	500-1200Hz, 0.5s/0.5s OFF x 3/1.5s OFF (AS 1670 Evacuation)
Tone type 10	550 Hz /440 Hz@ 0.5 Hz
Tone type 11	970 Hz, 0.5s ON / 0.5s OFFx 3/1.5s OFF (ISO 8201)
Tone type 12	2850 Hz, 0.5s ON/ 0.5s OFF x 3/1.5s OFF (ISO8201)
Tone type 13	1200 Hz – 500 Hz @ 1 Hz (DIN 33 404)
Tone type 14	400 Hz
Tone type 15	550 Hz, 0.7 s / 1000 Hz, 0.33 s
Tone type 16	1500 Hz - 2700 Hz @ 3 Hz
Tone type 17	750 Hz
Tone type 18	2400 Hz
Tone type 19	660 Hz
Tone type 20	660 Hz 1.8 s ON / 1.8 s OFF



Nová Dubnica, July 19th, 2024

Michal Mišiak
Head of CB NB No. 1293

Annex No. 2 to Certificate No. 1293 - CPR – 0462 Rev.3 from July 19th, 2024

Products parameters (Part 2)

Tone type 21	660 Hz 0.15 s ON / 0.15 s OFF
Tone type 22	510 Hz 0.25 s / 610 Hz 0.25s
Tone type 23	800/1000 Hz 0.5s each (1 Hz)
Tone type 24	250 Hz – 1200 Hz @ 12 Hz
Tone type 25	500 Hz – 1200 Hz @ 0.33 Hz
Tone type 26	2400 Hz – 2900 Hz @ 9 Hz
Tone type 27	2400 Hz – 2900 Hz @ 3 Hz
Tone type 28	800 Hz – 970 Hz @ 100 Hz
Tone type 29	800 Hz – 970 Hz @ 9 Hz
Tone type 30	800 Hz – 970 Hz @ 3 Hz
Tone type 31	800 Hz 0.25s ON / 1 s OFF
Tone type 32	600 Hz – 1100 Hz, 2.6s / 0.4s OFF
Number of tone types	32
Wire Gauge for terminals	2.5mm ²
Degree of protection	IP43C(EN54-3) with base B124
Degree of protection	IP 65(EN60529) with base WSB IP65
Operation temperature	-10°C ÷ +50°C
Relative humidity	(93±3)% @ +40°C
Dimensions	55x116mm
Weight	~ 183g
Color	white transparent
Coverage volume	W-2.4-6 class



Nová Dubnica, July 19th, 2024

Michal Mišiak
Head of CB NB No. 1293

056162

Annex No. 3 to Certificate No. 1293 - CPR – 0462 Rev.3 from July 19th, 2024

Essential characteristics	Harmonised technical specification			Performance
	EN 54-3:2001 EN 54-3:2001/ A1:2002 EN 54-3:2001/ A2:2006	EN 54-17:2005 EN 54-17:2005/ AC:2007	EN 54-23:2010	
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1 to C.5.3=N/A	cl. 5.2	cl. 4.3.1 to 4.3.7	Pass
Operational reliability	cl. 4.4 to 4.6, 5.4, C4=N/A	cl. 4	cl. 4.2.1 to 4.2.8	Pass
Durability of operational reliability and response delay: temperature resistance	cl. 5.5 to 5.9	cl. 5.4, 5.5	cl. 4.4.1.1 to 4.4.1.3	Pass
Durability of operational reliability: humidity resistance	cl. 5.8 to 5.10	cl. 5.6, 5.7	cl. 4.4.2.1 to 4.4.2.3	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	cl. 5.9 to 5.12	cl. 4.4.3.1 to 4.4.3.4	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	cl. 5.8	cl. 4.4.4	Pass
Durability of operational reliability: electrical stability	cl. 5.16	cl. 5.3, 5.13	cl. 4.4.5	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17	---	---	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0462	Original certificate issued	January 29 th , 2015
2	1293-CPR-0462 Rev.1	Added new brand name and change of one brand name	August 10 th , 2017
3	1293-CPR-0462 Rev.2	New location of the company	September 29 th , 2023
4	1293-CPR-0462 Rev.3	Editorial correction	July 19 th , 2024



Nová Dubnica, July 19th, 2024

Michal Mišiak
Head of CB NB No. 1293