



EVPU[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0539

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Conventional fire alarm manual call point SensoMAG MCP50 IP67, SCP2R IP67

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

**Teletek Electronics JSC
14A Srebarňa Str., 1407 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC
14A Srebarňa Str., 1407 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11:2001

EN 54-11:2001/A1:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on February 08, 2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, February 08, 2017

Marek H u d á k
Director NB

053043

Annex to Certificate No. 1293 - CPR – 0539 from February 08, 2017

Technical Specifications

SensoMAG MCP50 IP67 , SCP2R IP67 is a manual call point, designed for outdoor installations and IP67 endowments.

The call point is equipped also with a protective transparent cover for avoiding of fault or accidental activation.

Products parameters:

Operating voltage:	9+30VDC
Nominal operating voltage:	24VDC
Current consumption in alarm state	23mA/15V, 38mA/24V, 48mA/30V
Installation wires	2.5 mm ²
Relative humidity	≤ 93% @ +40°C
Material (plastic), colour	ABS, red
Type (according to EN 54-11,17):	A
Type of frangible element	Resettable (flexible)
Indication "Fire alarm"	red LED

Essential characteristics	Test specification	Harmonised technical specifications	Performance
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	EN 54-11:2001 EN 54-11/A1:2005	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8=N/A, 5.4, 5.5	EN 54-11:2001 EN 54-11/A1:2005	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8, 5.9	EN 54-11:2001 EN 54-11/A1:2005	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	EN 54-11:2001 EN 54-11/A1:2005	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11, 5.12, 5.19	EN 54-11:2001 EN 54-11/A1:2005	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11, 5.13	EN 54-11:2001 EN 54-11/A1:2005	Pass
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	EN 54-11:2001 EN 54-11/A1:2005	Pass

Nová Dubnica, February 08, 2017



Marek H u d á k
Director NO