



DECLARATION OF CONFORMITY

We, **Teletek Electronics JSC**
Address: 2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: **SensoMAG R20**

Description: **Conventional fire alarm Rate-of-Rise Head Detector**

Complies to the following standards:

EN 54-5:2017
EN 54-5:2017/A1:2018
EN 55032:2015
EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011
REACH № 1907/2006

And the following Directives:

2014/30/EU - EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 04.2018

Certificate:

№ 1293–CPR-0639-Rev.2 of November 6th, 2023 from Notified body № 1293 EVPU

Test report:

№ C08/22/0001/4203/SL-3 of August 31, 2022 from Notified body № 1293 EVPU

Note: To be used in conjunction with base B12L/U, B24, B24D, B24RD or B24-HP.

2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
13.12.2023

Yuliy Iliev
Quality Manager

