



## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 14A, Srebarna Str.  
1407 Sofia, Bulgaria

**Declares that the**

**Product:** SensoMAG S30

**Description:** Conventional fire alarm optical-smoke detector

**Complies to the following standards:**

EN 54-7:2018

EN 55032:2015

EN 50130-4:2011/A1:2014

**The following Regulation:**

CPR № 305/2011

REACH No 1907/2006

**And the following Directives:**

2014/30/EU - EMC

2011/65/EU – RoHS II

**Additional information:**

**First date of production:** 04.2018

**Certificate:**

№ 1293–CPR-0637-Rev.1

of August 31, 2022 from Notified body № 1293 EVPU

**Test report:**

№ C08/22/0001/4204/SL-2

of August 31, 2022 from Notified body № 1293 EVPU

**Note:** To be used in conjunction with base B12L/U, B24, B24D, B24RD or B24-HP.

1407 Sofia,  
14A, Srebarna Str.  
15.09.2022

Yuliy Iliev  
Quality Manager

