

CERTIFICATE

No: 000222/03

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we
Telefication B.V. certify that the product

TL2803GRE-EU

is in conformity with the following standard(s)

EN 50131-10 June, 2014

Alarm systems - Intrusion and hold-up systems - Part 10: Application specific requirements for Supervised
Premises Transceiver (SPT)

EN 50136-2 August, 2013

Alarm systems - Alarm transmission systems and equipment - Part 2: Requirements for Supervised Premises
Transceiver (SPT)

Digital Security Controls, a division of Tyco Safety Products

3301 Langstaff Road
L4K 4L2 CONCORD
Canada

is authorised to use the CERTALARM Mark on the above mentioned product.
This certificate is valid until:
10 September 2024

Zevenaar, 11 September 2020

Signed on behalf of Telefication B.V.



Bernard Meijer
Project manager



CERTIFICATE

No: 000222/03 - Annex No 1

Takes into account the following product and variants:

- Product description: Dual IP/Cellular Alarm Communicator
- Trademark: DSC
- Type designation: TL2803GRE-EU
- Hardware version: UA685 Rev. 01
- Software version: Ver. 5.0

- Product description: Dual IP/Cellular Alarm Communicator
- Trademark: DSC
- Type designation: TL2803GE-EU
- Hardware version: UA685 Rev. 01
- Software version: Ver. 5.0

- Product description: 3G/GSM-GPRS Cellular Alarm Communicator
- Trademark: DSC
- Type designation: 3G2080RE-EU
- Hardware version: UA685 Rev. 01
- Software version: Ver. 5.0

- Product description: 3G/GSM-GPRS Cellular Alarm Communicator
- Trademark: DSC
- Type designation: 3G2080E-EU
- Hardware version: UA685 Rev. 01
- Software version: Ver. 5.0

- Product description: IP alarm communicator
- Trademark: DSC
- Type designation: TL280RE
- Hardware version: UA685 Rev. 01
- Software version: Ver. 5.0

- Product description: IP alarm communicator
- Trademark: DSC
- Type designation: TL280E
- Hardware version: UA685 Rev. 01
- Software version: Ver. 5.0

The optional features of the specifications that are included in the product and test report:

Equipment Security grade: 2
Equipment Environmental class: II
Equipment class: Fixed
SPT structure : Type Y
ATS category : Custom category C

CERTIFICATE

No: 000222/03 - Annex No 1

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Factory location:

TYCO INTERNATIONAL DE MEXICO S DE R.L. DE C.V.
ANTONIO MEUCCI YG GONZALEZ CAMARENA # 10002/PARQUE INDUSTRIAL LA VENTANA
87569, Matamoros
Mexico

Storage location:

AnB Rimex SA
Rue de l'Abbaye 89
4040 Herstal
Belgium

Applied Standards

EN 50130-5 June, 2011

Alarm systems - Part 5: Environmental test methods

EN 50130-4+A1 October, 2014

Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

EN 50131-1+A1+A2 May, 2017

Alarm systems - Intrusion and hold-up systems - Part 1: System requirements

EN 50136-1+A1 November, 2018

Alarm systems - Alarm transmission systems and equipment - Part 1: General requirements for alarm transmission systems

Test Reports:

- Telefication B.V.: 160300642-002-Ver 1.00, 28 June 2016
- Telefication B.V.: 160300642-001-Ver 1.00, 28 June 2016
- Telefication B.V.: 20134020800 -Ver1.00, 19 January 2015
- Telefication B.V.: 20134033800-Ver 1.00, 03 December 2014
- Nemko Canada Inc.: HS2 System EN50130-4 Nemko Test Report 238276-1R1TRFEMC, 09 January 2014

CERTIFICATE

No: 000222/03 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.