

INCERT CERTIFICATE

Certificate No: C-001-0665/d

In compliance with the procedure specified in RD_014, Telefication declares that the stated alarm equipment complies with the Technical specifications as listed in this certificate.

Product description: **8-16 Zone DGP Expander**

Trademark: **Interlogix**

Type designation: **AT1211E**

Serial No: **N/A**

Hardware / Software version: **1051623 / 2.8**

Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003DH Weert**

Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security EMEA bvba**

Address: **De Kleetlaan 3**

City: **1831 Diegem**

Country: **Belgia**

Expiry date: **11 December 2025**

This INCERT certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the full responsibility of the manufacturer.

Zevenaar, 12 December 2019



Jan Willem Verwoert
Project Manager



Remarks and observations

The following conditions are applicable:

8 Zones Expander module with variants ATS1211E and ATS1210E.

The units are identical in schematic and PCB lay-out, only the enclosure is different.

ATS1210E: Polycarbonate housing, dimensions 86 x 125 x 36 mm

ATS1211E: Metal housing with coating, dimensions 165 x 125 x 36 mm

Category: Interface

Security Grade: 3

Environmental class: II

Equipment class: Fixed

Applied standards:

- EN 50131-1:2006 + A1:2009 + A2:2017

- EN 50131-3:2009

- EN 50130-4:2011 + A1:2014

- EN 50130-5: 2011

Factory location:

United Technologies Safety Systems

No.80 Changjiang East Road

QETDZ Qinhuangdao

China

Documentation lodged for this INCERT certificate

Test Reports:

- Telefication: 151200964-013-Ver 1.00, 05 September 2016
- Telefication: 20133758800rev1.0, 28 November 2013
- Telefication: 20113464800_rev2, 22 October 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E1, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E2, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: Test report PX06911A Environmental durability, 28 January 2011

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

T 031/A1

February, 2018

Technical features and characteristics

The product includes the following features and characteristics:

The product as described in this certificate includes the following type designations:

- Product description: 8-16 Zone DGP Expander
- Trademark: Interlogix
- Type designation: AT1211E
- Hardware version: 1051623
- Software version: 2.8
- Serial number: N/A

- Product description: 8-16 Zone DGP Expander
- Trademark: Interlogix
- Type designation: AT1210E
- Hardware version: 1051623
- Software version: 2.8
- Serial number: N/A