



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0570

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR)*, this certificate applies to the construction product

Indoor fire sounder and visual alarm device DSE3-23 HW, DSE3-23 HQ

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Notifier Italia S.r.l.

Via Grandi, 22, 20097 San Donato Milanese (MI), Italy

and produced in the manufacturing plant

VENITEM S.R.L.

Via del Lavoro, 10, 30030 Salzano (VE), Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 54-3: 2001

EN 54-3:2001/A1:2002

EN 54-3:2001/A2:2006

EN 54-23: 2010


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on February 2nd, 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, February 2nd, 2018

053233



Marek Hudák
Director NB

Annex to Certificate No. 1293 - CPR – 0570 from February 2nd, 2018

General Information:


DSE3-23 HW, DSE3-23 HQ are devices designed for acoustic and optical notice in fire alarm systems.

Technical specifications:

Nominal Voltage supply: 24Vdc
 Operating Voltage range: 20Vdc – 30Vdc
 Max Current consumption: 130mA @Vdc=24V (DIP1=OFF 110mA, DIP1=ON 130mA)
 Max Power consumption: 2,6W
 Enclosure protection degree: IP31C (Type A, for indoor use)
 Operating temperature: -10°C to +55°C
 Size: 155 x 100 x 53mm
 Weight: 250g

Products parameters:

Essential characteristics	Harmonised technical specification		Performance
	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	EN 54-23:2010	
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1 to C.5.3=N/A	cl. 4.3.1 to 4.3.6, 4.3.7=N/A	Pass
Operational reliability	cl. 4.4, 4.5, 4.6, 5.4, C.4=N/A	cl. 4.2.1 to 4.2.8	Pass
Durability of operational reliability: temperature resistance	cl. 5.5, 5.6=N/A, 5.7, 5.8, 5.9	cl. 4.4.1.1, 4.4.1.2=N/A, 4.4.1.3	Pass
Durability of operational reliability: humidity resistance	cl. 5.8, 5.9, 5.10=N/A	cl. 4.4.2.1, 4.4.2.2, 4.4.2.3=N/A	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	cl. 4.4.3.1 to 4.4.3.4	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	cl. 4.4.4	Pass
Durability of operational reliability: electrical stability	cl. 5.16	cl. 4.4.5	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17	—	Pass



Nová Dubnica, February 2nd, 2018

Marek Hudák
Director NB