



DECLARATION OF CONFORMITY

LF20W Fire Alarm Panel

We,

SYNAPS TECHNOLOGY SRL
Via Pietraferrata, 9/1
IT-34147 Trieste TS
Italy

Declare under our sole responsibility that the product:

LF20W Fire Alarm Panel (EN-54-3)

Is in conformity with the requirements of the directives:

REG UE 305/2011 Construction Products (CPR)
DIR 2004/108/CE Electromagnetic Compatibility (EMC)
DIR 2011/65/UE Restrictions of hazardous Substances (RoHS II)

The conformity with the requirements of the directives above have been verified against the following harmonized standards:

EN 54-3:2001/A1:2002/A2:2006 "Fire detection and fire alarm systems - Part 3: Fire alarm devices: Sounders".

EN 50130-4:2011/A1:2014 "Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems.

EN 50581:2012 "Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances.

All the technical documentation relevant to the product will be held at:

SYNAPS TECHNOLOGY SRL
Via Pietraferrata, 9/1
IT-34147 Trieste TS
Italy

Trieste, 20/06/2017



Massimo Defendi, Managing Director

