

DECLARATION OF PERFORMANCE

DoP2013/0002

According to the Construction Products Regulation EU no. 305/20011

| | | |
|---|---|---|
| 1 | Unique Identification code of the product | PM705C |
| 2 | Type, batch or serial number or any other element allowing identification of the construction product | Products are provided a batch manufacturing code based on date format |
| 3 | Intended use or uses of the construction product | Battery backed up Power supply for Fire Detection, signaling and indication equipment |
| 4 | Name, registered trade name or registered trade mark and contact address of the manufacturer | Elmdene International Limited 3 Keel Close, Interchange Park, Portsmouth, PO3 5QD, UK |
| 5 | Where applicable, name and contact address of the authorised representative | UTC Fire and Security BV Kelvinstraat 7, NL-8003 DH, Weert, The Netherlands |
| 6 | System or systems of assessment and verification of constancy of performance | System 1 testing |
| 7 | Name and Identification of notified body | VDS CE 0786 performed type testing and the initial inspection of the manufacturing plant and factory production control |
| | Date of compliance and continuing approval | 26 th June 2009 |
| | Under System | Level 1 - Factory Production Control |
| | CPD EC Certificate | 0786- CPD- 20787 |
| 8 | In case of declaration of performance concerning a construction product for which European Technical Assessment has been issued | Not applicable. |

9. Declared performance

| Essential Characteristics | Performance | Standard |
|---|-------------|----------------------------------|
| Performance of Power Supply | Pass | EN 54-4:1997 + A1:2002 + A2:2006 |
| Operational reliability | Pass | EN 54-4:1997 + A1:2002 + A2:2006 |
| Durability of operational reliability: temperature resistance | Pass | EN 54-4:1997 + A1:2002 + A2:2006 |
| Durability of operational reliability: vibration resistance | Pass | EN 54-4:1997 + A1:2002 + A2:2006 |
| Durability of operational reliability: electrical stability | Pass | EN 54-4:1997 + A1:2002 + A2:2006 |
| Durability of operational reliability: humidity resistance | Pass | EN 54-4:1997 + A1:2002 + A2:2006 |
| | | |

10. The performance of the Product Identified in (1), (2) above, is in conformity with the declared performance in (9).

This declaration of Performance is issued under the sole responsibility of the manufacturer identified in (4)

For and on behalf of Elmdene International Ltd



Hugh Devereux – Technical Director

Date: 24th April 2013

Portsmouth - United Kingdom