

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: IRIS/SIMPO Repeater
Derivative variants: IRIS8 (0) S, iRIS8 (0)
Description: Addressable Fire Alarm Repeater Panel

Complies with the following standards:

EN 54-2:1997; EN 54-2:1997/AC:1999; EN 54-2:1997/A1:2006
EN 54-4:1997; EN 54-4:1997/AC:1999; EN 54-4:1997/A1:2002
EN 54-4:1997/A2:2006
EN IEC 62368-1:2018
EN 55032:2015; EN 55032:2015/A11:2020 (Class A)
EN IEC 61000-3-2:2019
EN 61000-3-3:2013; EN 61000-3-3:2013/A1:2019
EN 50130-4:2011; EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC
2014/35/EU- LVD
2011/65/EU- RoHS II

Additional information:

First date of production: 03.2021

Certificate:

№ 1293-CPR-0790 of March 15, 2021 from Notified body № 1293 EVPU

Test report:

№ C08/20/0033/4202,4206/SL of March 15, 2021 from Notified body № 1293 EVPU

1407 Sofia,
14A, Srebarna Str.
16.04.2021

Yuliy Iliev
Quality Manager

