

# Certificate of Constancy of Performance

**Intertek**

## 0359-CPR-00272

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

**Product(s):** SmartCell range of range of Wireless control panels  
(refer to attached appendix for details and conditions)

**placed on the market under the name or trade mark of:** EMS Security Group Limited  
Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ, United Kingdom

**and produced in the manufacturing plant(s):** EMS Security Group Limited (EMSSECUK.01)  
Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ, United Kingdom

**Intended use:** Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN54-2:1997+A1:2006**

**EN54-4:1997+A1:2002+A2:2006**

**EN54-25:2008+AC:2012**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **16<sup>th</sup> August 2019** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

**Notified Body**  
**0359**

Intertek Testing & Certification Limited  
Cleeve Road, Leatherhead  
Surrey, KT22 7SA  
Tel: + 44 (0)1372 370900  
Fax: +44 (0)1372 370977  
E-mail: [cpd.uk@intertek.com](mailto:cpd.uk@intertek.com)

Nick Jones  
Certification Officer



Date 16/08/2019  
Issue 1

[www.intertek.com](http://www.intertek.com)

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## 0359-CPR-00272

### Appendix to Certificate of Constancy of Performance 0359-CPR-00272

The details and conditions of use for the SmartCell range of range of wireless control panels, placed on the market under the name or trade mark of:

#### EMS Security Group Limited

Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

#### Products compliant with EN54-2:1997+A1:2006, EN54-4:1997+A1:2002+A2:2006 and EN54-25:2008+AC:2012:

Model	Manufacturing Location	Description
SC-11-1201-0000	EMSSECUK.01	SmartCell Wireless Control Panel (without communication card) Comprising: P05353 0G Processor PCB P05354-0F Interface PCB P05205 Enclosure Back box P05206 Enclosure lid moulding P05390 Nordic key drum P05392 Nordic key drum retainer P05369 2 x Sliding cover SC-60-1000 Universal PSU (SmartCell variant) Batteries 1x 6V 4Ah Yuasa NP4-6

#### Products compliant with EN54-2:1997+A1:2006 and EN54-25:2008+AC:2012:

Model	Manufacturing Location	Description
SC-11-2201-0000	EMSSECUK.01	SmartCell Wireless Control Panel (24 VDC version without communication card) Comprising: P05353 0G Processor PCB P05354-0F Interface PCB P05205 Enclosure Back box P05206 Enclosure lid moulding P05390 Nordic key drum P05392 Nordic key drum retainer P05369 2 x Sliding cover P05488-01 24V PSU PCB

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SA  
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: [cpd.uk@intertek.com](mailto:cpd.uk@intertek.com)

0359-CPR-00272  
Issue 1

[www.intertek.com](http://www.intertek.com)

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,  
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## 0359-CPR-00272

### Appendix to Certificate of Constancy of Performance 0359-CPR-00272 (continued)

#### Options with requirements evaluated as being compliant:

Clause 7.8	Output to fire alarm devices
Clause 7.9	Control of fire alarm routing equipment
Clause 7.11	Delays to outputs
Clause 7.12	Dependencies on more than one alarm signal
Clause 8.3	Fault signals from points
Clause 8.9	Output to fault warning routing equipment
Clause 9.5	Disablement of addressable points
Clause 10	Test Condition

#### Ancillary functions:

<b>Inputs:</b>	2 x Monitored Inputs (Input 1 & 2) programmable
	1 x RS232
	1 x Ethernet
	1 x GSM/GPRS
<b>Outputs:</b>	1 x Volt-free contact fault relay (programmable)
	1 x Volt-free contact fire alarm relay (programmable)

#### Packing variants:

Additional packing code information following the model number:  
XX-YY-ZZZZ-BBBB-CC

Product Family:	X
Product Line:	X
Group:	Y
Type:	Y
Power:	Z
Colour:	Z
Indication:	Z
Variant:	Z
Branding	B
Branding	B
Branding	B
Branding	B
Country Code	C
Country Code	C

The 4-digit branding code relates to packing codes for branded variants. Details are maintained in controlled document - EMS Document BRAND-0001 EMS SmartCell Product Range - Customer Branding Specification.

The 2-digit Country Code relates to packing codes for specific country variants.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SA  
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: [cpd.uk@intertek.com](mailto:cpd.uk@intertek.com)

0359-CPR-00272  
Issue 1

[www.intertek.com](http://www.intertek.com)

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,  
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

### Appendix to Certificate of Constancy of Performance 0359-CPR-00272 (continued)

#### Conditions of use:

Suitable for indoor applications only

#### General notes:

1. Evaluated under Intertek project number 101317801.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.