

## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 14A, Srebarna Str.  
1407 Sofia, Bulgaria

**Declares that the**

**Product:** SensoIRIS MC-Z, SensoIRIS MC-Z IP55  
**Description:** Addressable fire alarm module conventional zone with built-in isolator module

**Complies to the following standards:**

EN 54-17:2005; EN 54-17:2005/AC:2007  
EN 54-18:2005; EN 54-18:2005/AC:2007  
EN 55032:2015  
EN 50130-4:2011; EN 50130-4:2011/A1:2014

**The following Regulation:**

CPR № 305/2011  
REACH № 1907/2006

**And the following Directives:**

2014/30/EU- EMC  
2011/65/EU- RoHS II

**Additional information:**

**First date of production:** 05.2020

**Certificate:**

№1293-CPR-0701 of October 28, 2020 from Notified body № 1293 EVPU

**Test report:**

№ 9-0023/20 of October 28, 2020 from Notified body № 1293 EVPU

1407 Sofia,  
14A, Srebarna Str.  
24.11.2020

Yuliy Iliev  
Quality Manager

