



DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: SensoMAG F10
Description: Conventional Fire Alarm Fixed Temperature Detector

Complies to the following standards:

EN 54-5:2017
EN 54-5:2017/A1:2018
EN 55032:2015
EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU - EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 04.2018

Certificate:

№ 1293–CPR-0641-Rev.1 of August 31, 2022 from Notified body № 1293 EVPU

Test report:

№ C08/22/0001/4203/SL-4 of August 31, 2022 from Notified body № 1293 EVPU

Note: To be used in conjunction with base B12L/U, B24, B24D, B24RD or B24-HP.

1407 Sofia,
14A, Srebarna Str.
15.09.2022

Yuliy Iliev
Quality Manager

