

**Date of Issue – 15<sup>th</sup> August 2016**

**EU DECLARATION OF CONFORMITY**

1. Object of the Declaration of Conformity:

**Product Family: Series 65 Detectors**

Part Number	Brand	Product Description
55000-120	Series 65 Heat	A1R Heat Detector with Flashing LED & Magnetic Test Switch
55000-121	Series 65 Heat	A1R Heat Detector with Flashing LED
55000-122	Series 65 Heat	A1R Heat Detector
55000-125	Series 65 Heat	BR Heat Detector with Flashing LED & Magnetic Test Switch
55000-126	Series 65 Heat	BR Heat Detector with Flashing LED
55000-127	Series 65 Heat	BR Heat Detector
55000-130	Series 65 Heat	CR Heat Detector with Flashing LED & Magnetic Test Switch
55000-131	Series 65 Heat	CR Heat Detector with Flashing LED
55000-132	Series 65 Heat	CR Heat Detector
55000-135	Series 65 Heat	CS Heat Detector with Flashing LED & Magnetic Test Switch
55000-136	Series 65 Heat	CS Heat Detector with Flashing LED
55000-137	Series 65 Heat	CS Heat Detector
55000-208	Series 65 Ionisation	Ionisation Smoke Detector
55000-215	Series 65 Ionisation	Ionisation Smoke Detector with Flashing LED & Magnetic Test Switch
55000-216	Series 65 Ionisation	Ionisation Smoke Detector with Flashing LED
55000-217	Series 65 Ionisation	Ionisation Smoke Detector
55000-218	Series 65 Ionisation	Integrating Ionisation Smoke Detector with Flashing LED & Magnetic Test Switch
55000-219	Series 65 Ionisation	Integrating Ionisation Smoke Detector with Flashing LED

A HALMA COMPANY



Assessed to ISO 9001:2008  
LPCB Cert No. 010



Certificate No. 010  
See www.RedBookLive.com



Assessed to ISO 14001:2004  
Certificate number EMS 010

**Apollo Fire Detectors Limited**

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

t +44 (0)23 9249 2412 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

**www.apollo-fire.co.uk**

Apollo Fire Detectors Ltd. Registered in England No. 1483208

Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB339 055354

55000-220	Series 65 Ionisation	Integrating Ionisation Smoke Detector
55000-308	Series 65 Optical	Optical Smoke Detector
55000-315	Series 65 Optical	Optical Smoke Detector with Flashing LED & Magnetic Test Switch
55000-316	Series 65 Optical	Optical Smoke Detector with Flashing LED
55000-317	Series 65 Optical	Optical Smoke Detector

2. These products are manufactured at the premises of Apollo Fire Detectors Limited, 36 Brookside Road, Havant, Hampshire, England PO9 1JR.

3. This declaration is issued under the sole responsibility of the manufacturer.

4. The object of the declaration described above is in conformity with the relevant Union harmonization legislation:

2014/30/EU      EMC Directive  
2011/65/EU      Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)

5. References to the relevant harmonized standards used or references to the specifications in relation to which conformity is declared:

BS EN 61000-6-3: 2007+A1:      Electromagnetic compatibility (EMC). Generic standards.  
2011                                      Emission standard for residential, commercial and light-industrial environments

BS EN 50130-4:2011+A1:      Alarm systems. Electromagnetic compatibility. Product family  
2014                                      standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

6. References to the applicable test reports:

DE060032, BMA 00014, BMA 00018, BMA 99082, TR 4193, LSR 3087, LSR 3720, TR4210, TR4194, TR4201, TR4214, TR4222

This declaration is made for and on behalf of Apollo Fire Detectors by the Technical Director, Mr. Karl Westhead, who has been designated as the responsible person for the purpose of the Regulations.



Signature .....Mr. Karl Westhead – Technical Director