

# Certificate

of  
Conformity

No: 202330028/AA/00

Telefication declares that the listed product complies with the Technical standards and specifications as indicated under Annex 2 of this certificate.

Product description: **IRIS Addressable Fire Alarm System**  
Trademark: **Teletek Electronics**  
Type designation: **IRIS**  
Hardware / Software version: - / -

Manufacturer: **Teletek Electronics JSC**  
Address: **Srebarna Str. 14A**  
City: **1407 SOFIA**  
Country: **Bulgaria**

This certificate is granted to:

Name: **Teletek Electronics JSC**  
Address: **Srebarna Str. 14A**  
City: **1407 SOFIA**  
Country: **Bulgaria**

This certificate has THREE Annexes.

Zevenaar, 22 July 2020



Bernard Meijer  
Project manager



## Remarks and observations

The following conditions are applicable:

The following products have been involved in the compatibility assessment, as detailed in chapter 1.3 “*Scope of assessment*” of assessment report 200401719-001 (Ver. 3.00):

## CIE

### Fire Panels (EN 54-2 / EN54-4)

Product ID	Description	Classification*
Teletek Electronics		
IRIS (1-4) L M		
IRIS (1-4) L P	Intelligent Analogue Addressable	1
IRIS (0) Repeater M	Interactive Fire Alarm Control Panel	
IRIS (0) Repeater P		

## AUXILIARY DEVICES

### Detectors (EN 54-5 / EN 54-7 / EN 54-17)

Product ID	Description	Classification*
Teletek Electronics		
SensoIRIS T110	Intelligent Analogue Addressable Fire	1
MAGPRO-HD1	Alarm Heat Detector	
Belinda T110		
SensoIRIS S130	Intelligent Analogue Addressable Fire	1
MAGPRO-SD1	Alarm Optical Smoke Detector	
Belinda S130		
SensoIRIS M140	Intelligent Analogue Addressable Fire	1
MAGPRO-HSD1	Alarm Heat and Optical Smoke	
Belinda M140	Detector	
SensoIRIS M140 IS	Intelligent Analogue Addressable Fire	1
MAGPRO-HSD1iM	Alarm Heat and Optical Smoke	
Belinda M140 IS	Detector with built-in isolator module	
SensoIRIS S130 IS	Intelligent Analogue Addressable Fire	1
MAGPRO-SD1iM	Alarm Optical Smoke Detector with	
Belinda S130 IS	built-in isolator module	
SensoIRIS T110 IS	Intelligent Analogue Addressable Fire	1
MAGPRO-HD1iM	Alarm Heat Detector with built-in	
Belinda T110 IS	isolator module	
Vella M140	Intelligent Analogue Addressable Fire	1
	Alarm Heat and Optical Smoke	
	Detector	
Vella S130	Intelligent Analogue Addressable Fire	1
	Alarm Optical Smoke Detector	
Vella T110	Intelligent Analogue Addressable Fire	1
	Alarm Heat Detector	
Vella M140 IS	Intelligent Analogue Addressable Fire	1
	Alarm Heat and Optical Smoke	
	Detector with built-in isolator module	
Vella S130 IS	Intelligent Analogue Addressable Fire	1
	Alarm Optical Smoke Detector with	
	built-in isolator module	

Vella T110 IS	Intelligent Analogue Addressable Fire Alarm Heat Detector with built-in isolator module	1
SensoIRIS B124	Addressable Fire Base	1

### Manual Call Points (EN 54-11 / EN 54-17)

Product ID Teletek Electronics	Description	Classification*
SensoIRIS MCP150 MAGPRO-CPiM Belinda MCP150	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
SensoIRIS MCP150MR Belinda MCP150MR	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
SensoIRIS MCP150PR	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
SensoIRIS MCP150PB Belinda MCP150PB Belinda MCP150PR	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1
SensoIRIS MCP150 IP67 MAGPRO-CPiM IP67 Belinda MCP150 IP67	Intelligent Analogue Addressable Fire Alarm Manual Call Point with built-in isolator module	1

### Warning Devices (EN 54-3 / EN 54-17 / EN 54-23)

Product ID Teletek Electronics	Description	Classification*
SensoIRIS WS MAGPRO-WSS	Intelligent Analogue Addressable Fire Alarm Sounder	1
SensoIRIS WSOU MAGPRO-WS Belinda WSOU	Intelligent Analogue Addressable Fire Alarm Sounder	1
SensoIRIS WSOU IS MAGPRO-WSiM Belinda WSOU IS	Intelligent Analogue Addressable Fire Alarm Sounder with built-in isolator module	1
SensoIRIS WSST MAGPRO-WSS23 Belinda WSST	Intelligent Analogue Addressable Fire Alarm Sounder and Strobe	1
SensoIRIS WSST IS MAGPRO-WSS23iM Belinda WSST IS	Intelligent Analogue Addressable Fire Alarm Sounder and Strobe with built-in isolator module	1
SensoIRIS WSB IP65	Waterproof protected deep base	1
SensoIRIS BSOU MAGPRO-DBS	Intelligent Analogue Addressable Fire Alarm base with built-in sounder	1
SensoIRIS BSST MAGPRO-DBSS	Intelligent Analogue Addressable Fire Alarm base with built-in sounder and strobe /flash/	1

SF300	Conventional fire alarm outdoor sunder	1
SF3000		
SF400		
SF100 RSST	Conventional fire alarm sunder with strobe	1
Hera RSST		
Tera RSST		
Aura RSST		
SF100 RSND	Conventional fire alarm Sunder	1
Hera RSND		
Tera RSND		
Aura RSND		
SF100 WSST	Conventional fire alarm sunder with strobe	1
Hera WSST		
Tera WSST		
Aura WSST		

### I/O modules (EN 54-17 / EN 54-18)

Product ID	Description	Classification*
<b>Teletek Electronics</b>		
SensoIRIS MIO22	Module Inputs/ Outputs	1
SensoIRIS MIO 04	Intelligent Analogue Addressable Fire Alarm Module with 4 outputs with built-in isolator module	1
MAGPRO-0i4OiM		
Belinda MIO40	Intelligent Analogue Addressable Fire Alarm Module with 4 inputs with built- in isolator module	1
SensoIRIS MIO 40		
MAGPRO-4i0OiM		
Belinda MIO04		
SensoIRIS MISO	Isolator Module	1
MAGPRO-iM		
SensoIRIS MOUT	Intelligent Analogue Addressable Fire Alarm Monitored Output Module for Conventional Sounders with 4 inputs with built-in isolator module	1
MAGPRO-1OSiiM		
Belinda MOUT		
SensoIRIS MIO22M	Intelligent Analogue Addressable Fire Alarm Module with 2 inputs and 2 monitored outputs with built-in isolator module	1
SensoIRIS MIO22M		
IP55		
MAGPRO-2i2OiM M		
Belinda MIO22M		

### Power supply (EN54-4)

Product ID	Description	Classification*
<b>Teletek Electronics</b>		
IRIS PS72	Back-up Power Supply Unit	1

### Miscellaneous

Product ID	Description	Classification*
<b>Teletek Electronics</b>		
IRIS Printer	Thermal printer in a metal box	2

**\* Classification options:**

- **Component type 1: device performing EN54-1 defined functionality**
- **Component type 2: other types of devices connected to component type 1**

## Documentation lodged for this Certificate of Conformity

### Test Reports:

- Telefication B.V.: 200401719-001 (Ver. 3.00), 22 July 2020

### Product Documentation:

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 54-13:2017 + A1:2019

October, 2019

## Applied Standards

Not Applicable

**The product as described in this certificate includes the following type designations:**

- Product description: IRIS Addressable Fire Alarm System
- Trademark: Teletek Electronics
- Type designation: IRIS
- Hardware version: -
- Software version: -