

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: IRIS8

Big box - IRIS8 B, IRIS8 (1-8) B, iRIS8 (1-8) B

Small box - IRIS8 S, IRIS8 (1-8)L S, IRIS (1-4)L P, iRIS8 S

Extension box - IRIS8 S Ext, IRIS (1-8) Ext, iRIS8 S Ext

Description: Expandable Addressable Fire Alarm Control Panel

Complies with the following standards:

EN 54-2:1997; EN 54-2:1997/AC:1999; EN 54-2:1997/A1:2006

EN 54-4:1997; EN 54-4:1997/AC:1999; EN 54-4:1997/A1:2002

EN 54-4:1997/A2:2006

EN IEC 62368-1:2018

EN 55032:2015; EN 55032:2015/A11:2020 (Class A)

EN IEC 61000-3-2:2019

EN 61000-3-3:2013; EN 61000-3-3:2013/A1:2019

EN 50130-4:2011; EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011

REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC

2014/35/EU- LVD

2011/65/EU- RoHS II

Additional information:

First date of production: 03.2021

Certificate:

№ 1293-CPR-0790

of March 15, 2021 from Notified body № 1293 EVPU

Test report:

№ C08/20/0033/4202,4206/SL

of March 15, 2021 from Notified body № 1293 EVPU

1407 Sofia,
14A, Srebarna Str.
16.04.2021

Yuliy Iliev
Quality Manager

