

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No.

0370-CPR-3235

In compliance with Regulation (EU) Nr.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS. INPUT/OUPUT DEVICES.

TRADEMARK: **ARITECH** MODEL: **IU2055NC**. CONVENTIONAL ZONE MONITOR

Placed on the market under the name of:

CARRIER FIRE & SECURITY B.V.

KELVINSTRAAT, 7
6003 DH WEERT (NETHERLANDS)

And produced in the manufacturing plant:

CARRIER SAFETY SYSTEM (HEBEI) CO., LTD.

No. 80 CHANGJIANG EAST ROAD, QETDZ, QINHUANGDAO, HEBEI, CHINA 066004

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-18:2005; EN 54-18:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 15th February 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. As of 8th September 2023, this and all previous modifications are confirmed.

The monitoring assessment will be done before 31st July 2024

Bellaterra, 8th September 2023


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

0370-CPR-3235

Annexes according to **EN 54-18:2005, EN 54-18:2005/AC:2007**

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 18: INPUT/OUTPUT DEVICES.

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Functional test	5.1.4.	PASS
Performance and variation in supply parameters	5.2	PASS
Dry heat (operational)	5.3	PASS
Cold (operational)	5.4	PASS
Damp heat, cyclic (operational)	5.5	PASS
Damp heat, steady state (endurance)	5.6	PASS
Sulphur dioxide (SO ₂) corrosion (endurance)	5.7	PASS
Shock (operational)	5.8	PASS
Impact (operational)	5.9	PASS
Vibration, sinusoidal (operational)	5.10	PASS
Vibration, sinusoidal (endurance)	5.11	PASS
Electromagnetic Compatibility (EMC) Immunity tests	5.12	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

CERTIFICADO DE CONSTANCIA DE LAS PRESTACIONES

LGAI Technological Center, S.A. (APPLUS)
Organismo Notificado Nr. 0370

No. **0370-CPR-3235**

En cumplimiento con el Reglamento (UE) No.305/2011 del Parlamento Europeo y del Consejo de 9 de marzo de 2011 (Reglamento de Productos de Construcción o CPR), este certificado aplica al producto de construcción:

SISTEMAS DE DETECCIÓN Y ALARMA DE INCENDIOS. DISPOSITIVOS DE ENTRADA/SALIDA

MARCA: **ARITECH** MODELO: **IU2055NC**. MONITOR DE ZONA CONVENCIONAL

Puesto en el mercado por:

CARRIER FIRE & SECURITY B.V.

KELVINSTRAAT, 7
6003 DH WEERT (NETHERLANDS)

Y fabricado en la planta de producción:

CARRIER SAFETY SYSTEM (HEBEI) CO., LTD.

No. 80 CHANGJIANG EAST ROAD, QETDZ, QINHUANGDAO, HEBEI, CHINA 066004

Este certificado acredita que se han aplicado todas las disposiciones relativas a la evaluación y verificación de la constancia de las prestaciones descritas en el Anexo ZA de la norma:

EN 54-18:2005; EN 54-18:2005/AC:2007

bajo el sistema 1, y que el control de producción en fábrica realizado por el fabricante se evalúa para garantizar la constancia de las prestaciones del producto de construcción.

Este certificado fue emitido por primera vez el 15 de febrero de 2019 y su validez permanece mientras no se modifique significativamente la norma armonizada, el producto de construcción, los métodos de EVCP ni las condiciones de fabricación en la planta, a menos que sean suspendidos o retirados por el organismo de certificación de productos notificado. A fecha 8 de septiembre de 2023 se confirma éste y todas sus modificaciones anteriores.

El seguimiento se realizará antes de 31 de julio de 2024

Bellaterra, 8 de septiembre de 2023


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



Este documento carece de validez sin su anexo técnico, cuyo número coincide con el del certificado.

Puede comprobarse la validez de este certificado en nuestra página web: www.appluslaboratories.com/certified_products

El fabricante, después de completar el procedimiento de evaluación de la conformidad y la declaración de prestaciones, puede colocar el marcado CE bajo su responsabilidad

0370-CPR-3235

Anexo según **EN 54-18:2005, EN 54-18:2005/AC:2007**

SISTEMAS DE DETECCIÓN Y ALARMA DE INCENDIOS. PARTE 18: DISPOSITIVOS DE ENTRADA/SALIDA

CARACTERÍSTICAS ESENCIALES	CAPÍTULO Y APARTADOS EN ESTA NORMA EUROPEA	NIVELES Y/O CLASES MANDATADAS
Ensayo funcional	5.1.4.	PASA
Comportamiento y variación en los parámetros de funcionamiento	5.2	PASA
Calor seco (funcional)	5.3	PASA
Frío (operacional)	5.4	PASA
Calor húmedo cíclico (funcional)	5.5	PASA
Calor húmedo estado estacionario (resistencia)	5.6	PASA
Corrosión por dióxido de azufre	5.7	PASA
Choque (operacional)	5.8	PASA
Impacto (operacional)	5.9	PASA
Vibración sinusoidal (operacional)	5.10	PASA
Vibración sinusoidal (resistencia)	5.11	PASA
EMC	5.12	PASA

PASA; PND = Prestación No Determinada, NA = No Aplica