

## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 14A, Srebarna Str.  
1407 Sofia, Bulgaria

**Declares that the**

**Product:** MAG2 (Fire Line MAG2, AE/C5-2M)  
MAG2P (Fire Line MAG2P, AE/C5-2P)  
MAG4 (Fire Line MAG4, AE/C5-4M)  
MAG4P (Fire Line MAG4P, AE/C5-4P)

**Description:** Conventional Fire Alarm Control Panel

**Complies to the following standards:**

EN 54-2:1997/A1:2006  
EN 54-4:1997/A2:2006  
EN 60950-1:2006+A1:2010+A2:2013+A11:2009+A12:2011  
EN 55032:2015  
EN 61000-3-2:2006/A1:2009/A2:2009  
EN 61000-3-3:2008  
EN 50130-4:2011/A1:2014

**The following Regulation:**

CPR № 305/2011  
REACH No 1907/2006

**And the following Directives:**

2014/30/EC-EMC  
2011/65/EU-RoHS II  
2014/35/EU-LVD

**Additional information:**

**First date of production:** 01.2016

**Certificate:**

№ 1293-CPR-0510 of January 15, 2016 from Notified body № 1293 EVPU

**Test report:**

№ 90084/2014 of February 12, 2015 from Notified body № 1293 EVPU

1407 Sofia,  
14A, Srebarna Str.  
27.06.2017

Yuliy Iliev  
Quality Manager

