



DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: Natron MD
Description: Wireless addressable fire alarm combined (heat and optical smoke) detector
Complies with the following standards:

EN 54-5:2017
EN 54-5:2017/A1:2018
EN 54-7:2018
EN 54-25:2008
EN 54-25:2008/AC:2012

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC
2014/35/EU- LVD
2011/65/EU- RoHS II

Additional information:

First date of production: 25.09.2023

Certificate:

№ 1293-CPR-0870 of 25.09.2023 from Notified body № 1293 EVPÚ a.s.

Test report:

№ 0-0077E/23 of 20.03.2023 from SNAS Reg. No. 010/S-042
№ 9-0009/1/23 of 20.03.2023 from SNAS Reg. No. 010/S-042.
№ 9-0009/2/23 of 17.04.2023 from SNAS Reg. No. 010/S-042
№ 9-0009/23 of 20.03.2023 from SNAS Reg. No. 010/S-042

2, Iliyansko shose str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
26.09.2023

Yuliy Iliiev
Quality Manager



1293

