

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: SensoIRIS WS
Description: Intelligent analogue addressable fire alarm wall sounder and strobe

Complies to the following standards:

EN 55032:2015
EN 50130-4:2011; EN 50130-4:2011/A1:2014
EN 54-3:2001
EN 54-3:2001/A1:2002
EN 54-3:2001/A2:2006
EN 54-17:2005; EN 54-17:2005/AC:2007

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU – EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 07.2017

Certificate:

№1293–CPR-0404 Rev. 1 of August 11, 2017 from Notified body № 1293 EVPU

Test report:

№ 90034/2017 of August 8, 2017 from Notified body № 1293 EVPU

Note: Sounder SensoIRIS WS is compatible with fire bases SensoIRIS B124 and SensoIRIS WSB IP65

1407 Sofia,
14A, Srebarna Str.
24.11.2020

Yuliy Iliev
Quality Manager

