

# Declaración de prestaciones

## Nº:2-5-086

1.- Nombre y código de identificación:

**VSN 2Plus-4-8-12**

**Equipos de control e indicación para sistemas de detección y alarma de incendios en edificios.**

2.- Nombre y dirección del fabricante

**VAT=B-81838047**

**Laureà Miró nº:401 nave:7**

**08980 St Feliu de Llobregat (Barcelona)**

**España**

3.- Uso previsto:

**Seguridad contra incendios**

4.- Sistema de evaluación y verificación de la constancia de las prestaciones:

**Sistema 1**

5.- Organismo notificado:

**ANPI 1134**


**Inspección anual en fábrica**

**Certificado de conformidad 1134-CPD-0086 18-9-2012**

6.- Prestaciones declaradas:

Características esenciales	Prestaciones	Especificaciones técnicas armonizadas	
		EN 54-2:1997/A1:2006	EN 54-4:1997/A1:2002+A2:2006
Comportamiento frente a incendios	Pasa	4,5,7	
Intervalo de respuesta (tiempo de respuesta al fuego)	Pasa	7.1, 7.7, 7.11, 7.12	
Seguridad operacional	Pasa	4,5,6,7,8,9,10,11,12,13,14	
Duración de la seguridad operacional y retardo a la respuesta; resistencia a la temperatura	Pasa	15.4	9.5
Duración de la seguridad operacional; resistencia a la vibración	Pasa	15.6, 15.7, 15.15	9.7, 9.8, 9.15
Duración de la seguridad operacional; resistencia a la humedad	Pasa	15.5, 15.14	9.6, 9.14
Duración de la seguridad operacional; estabilidad eléctrica	Pasa	15.8 a 15.13	9.9 a 9.13
Comportamiento del suministro de alimentación	Pasa		4,5,6
Fiabilidad en el funcionamiento	Pasa		4,5,6,7,8

- Las prestaciones del producto identificado en el punto 1 son conformes con las prestaciones declaradas en el punto 6.
- La presente declaración de prestaciones se emite bajo la única responsabilidad del fabricante indicado en el punto 2.
- Firmado por y en nombre del fabricante por:



Jordi Jsern  
Gerente

St Feliu de Llobregat a 1 de Julio de 2013

# Declaration of Performance

**Nº:2-5-086**

1.- Unique identification code of the product type:

**VSN 2Plus-4-8-12**

**Fire detection and alarm panel**

2.- Contact address of manufacturer

**VAT=B-81838047**

**Laureà Miró nº:401 nave:7**

**08980 St Feliu de Llobregat (Barcelona)**

**España**

3.- Intended use:

**Fire detection and fire alarm systems installed in buildings.**

4.- System of assessment and verification of constancy of performance:

**System 1**

5.- The notified body:

**ANPI 1134**

**Initial inspection of the manufacturing plant**

**EC Certificate of Conformity 1134-CPD-0086 18-9-2012**

6.- Declared performance:

Essential characteristics	Performance	Harmonised Technical specification	
		EN 54-2:1997/A1:2006	EN 54-4:1997/A1:2002+A2:2006
Performance under fire conditions	Pass	4,5,7	
Response delay (response time to fire)	Pass	7.1, 7.7, 7.11, 7.12	
Operational reliability	Pass	4,5,6,7,8,9,10,11,12,13,14	
Constancy of operational reliability: Temperature resistance	Pass	15.4	9.5
Constancy of operational reliability: Vibration resistance	Pass	15.6, 15.7, 15.15	9.7, 9.8, 9.15
Constancy of operational reliability: Humidity resistance	Pass	15.5, 15.14	9.6, 9.14
Constancy of operational reliability: Electrical stability	Pass	15.8 a 15.13	9.9 a 9.13
Performance of power supply	Pass		4,5,6
Operational reliability	Pass		4,5,6,7,8

- The performance of the product identified in points 1 is in conformity with the declared performance in point 6.
- This declaration of performance is issued under the sole responsibility of manufacturer identified in point 2.
- Name and function:



Jordi Isern  
Manager

St Feliu de Llobregat, 1 of July of 2013