

Declaration of performance

№ 065/2017

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

IRIS (1-4) L P

IRIS (1-4) L M

2. *Type Number:*

IRIS (1-4) L P

IRIS (1-4) L M

Description:

Addressable Fire Alarm Control Panel

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

Fire detection and fire alarm systems installed in and around buildings

4. *Manufacturer*

Teletek Electronics JSC

14A Srebarna Str.

1407 Sofia, Bulgaria

5. *Trading Company*

Teletek Electronics JSC

14A Srebarna Str.

1407 Sofia, Bulgaria

6. *System of assessment*

System 1

7. *Notified Body*

BRE Global Assurance (Ireland) Limited

DCU Alpha, Old Finglas Road, Glasnevin, Dublin, D11 KXN4, Ireland

Notified Body Number

2831

Performed **the prescribed tests and evaluation of factory production control according to system 1 and issued the following certificate**

EC Certificate Number

2831-CPR-F1672

8. *No European Technical Assessment has been issued for this product.*

9. *Declared performance*

Essential characteristics	Performance	Harmonized technical specification EN 54-2:1997/A1:2006
Performance under fire conditions	Pass	4, 5, 7
Response delay (response time to fire)	Pass	7.1, 7.7, 7.11, 7.12
Operational reliability	Pass	4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14
Durability of operational reliability, Temperature resistance	Pass	15.4
Durability of operational reliability, Vibration resistance	Pass	15.6, 15.7, 15.15
Durability of operational reliability, Electrical stability	Pass	15.8-15.13
Durability of operational reliability: humidity resistance	Pass	15.5, 15.14

Essential characteristics	Performance	Harmonized technical specification EN 54-4:1997/A1:2002 EN 54-4:1997/A2:2006
Performance of power supply	Pass	4, 5, 6
Operational reliability	Pass	4, 5, 6, 7, 8
Durability of operational reliability, Temperature resistance	Pass	9.5
Durability of operational reliability, Vibration resistance	Pass	9.7, 9.8, 9.15
Durability of operational reliability, Electrical stability	Pass	9.9-9.13
Durability of operational reliability: humidity resistance	Pass	9.6, 9.14

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia,
14A, Srebarna Str.
20.11.2019

Yuliy Iliev
Quality Manager

