

Declaration of Conformity

Document Number: 0832-CPR-F0008

Issuer's Name: Texecom Ltd

Issuer's address: Bradwood Court, St Crispin Way, Haslingden, Great Britain BB4 4PW

Object of the declaration:

Fire Alarm Device – Sounder and Visual Alarm Device for fire detection and fire alarm systems for buildings

Type A: Indoor use (shallow base) IP21; Type A: (deep base) IP65

Part No:	Product Description
ESCA3000R	Red Enclosure C-3-15 Conventional Type A/B Mounted Sounder white light LED visual alarm device
ESCA3000W	White Enclosure C-3-15 Conventional Type A/B Mounted Sounder white light LED visual alarm device

The object of the declaration described above is in conformity with the requirement of the following documents:

Documents No:	Title	Edition/Date of Issue
BS EN 61000-6-3	Electromagnetic compatibility (EMC). Generic standards. Emission standard for residential, commercial and light-industrial environments.	2007
BS EN 50130-4	Alarm systems. Electromagnetic compatibility. Product family standard. Immunity requirements for components of fire, intruder and social alarm systems.	1996 + A1:1998 + A2:2003
EN54-3	Fire detection and fire alarm systems. Fire alarm devices. Sounders	2001 +A1:2002 +A2:2006 Annex ZA
EN54-23	Fire detection and fire alarm systems – Part 23: Fire alarm devices – Visual alarm devices	2010

Additional Information:

Following the provisions of 305/2011/EEC (Construction Products Regulations) and 2004/108/EC (EMC Directive)

Notified Body No. 0832 BRE Certification Ltd and LPCB, Watford WD25 9XX.

This declaration is submitted by:



Jim Ludwig
Managing Director
31st October 2013



Texecom
Designed to Perform

Declaration of Conformity

Document Number: 0832-CPR-F0147

Issuer's Name: Texecom Ltd

Issuer's address: Bradwood Court, St Crispin Way, Haslingden, Great Britain BB4 4PW

Object of the declaration:

Fire Alarm Device – Sounder and Visual Alarm Device for fire detection and fire alarm systems for buildings

Type A: Indoor use (shallow base) IP21; Type A: (deep base) IP65

Part No:	Product Description
ESFA2000R	Red Enclosure C-3-8.9 Conventional Type A/B Mounted Sounder Red light LED visual alarm device
ESFA2000W	White Enclosure C-3-8.9 Conventional Type A/B Mounted Sounder Red light LED visual alarm device

The object of the declaration described above is in conformity with the requirement of the following documents:

Documents No:	Title	Edition/Date of Issue
BS EN 61000-6-3	Electromagnetic compatibility (EMC). Generic standards. Emission standard for residential, commercial and light-industrial environments.	2007
BS EN 50130-4	Alarm systems. Electromagnetic compatibility. Product family standard. Immunity requirements for components of fire, intruder and social alarm systems.	1996 + A1:1998 + A2:2003
EN54-3	Fire detection and fire alarm systems. Fire alarm devices. Sounders	2001 +A1:2002 +A2:2006 Annex ZA
EN54-23	Fire detection and fire alarm systems – Part 23: Fire alarm devices – Visual alarm devices	2010

Additional Information:

Following the provisions of 305/2011/EEC (Construction Products Regulations) and 2004/108/EC (EMC Directive)

Notified Body No. 0832 BRE Certification Ltd and LPCB, Watford WD25 9XX.

This declaration is submitted by:



Jim Ludwig
Managing Director
31st October 2013



Texecom
Designed to Perform