

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Notified Body Nr. 0370

No.

0370-CPR-1277

In compliance with Regulation (EU) Nr.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEM. SHORT CIRCUIT ISOLATORS

MODEL: **KZ715I. KILSEN**

Placed on the market under the name of:

CARRIER FIRE & SECURITY B.V.

KELVINSTRAAT, 7
6003 DH WEERT (NETHERLANDS)

And produced in the manufacturing plant:

CARRIER SAFETY SYSTEM (HEBEI) CO., LTD.

No. 80 CHANGJIANG EAST ROAD, QETDZ, QINHUANGDAO, HEBEI, CHINA 066004

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-17:2005; EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 23rd March 2012 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. As of 5th August 2022, this and all previous modifications are confirmed.

The monitoring assessment will be done before 31st July 2023

Bellaterra, 5th August 2022


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility



0370-CPR-1277

Annex according to **EN 54-17:2005; EN 54-17:2005/AC:2007**

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 17: SHORT CIRCUIT ISOLATORS

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Compliance	4.1	PASS
Integral status indication	4.2	PASS
Connection of ancillary devices	4.3	PASS
Monitoring of detachable short-circuit isolators	4.4	NA
Manufacturer's adjustments	4.5	PASS
On-site adjustments	4.6	NA
Marking	4.7	PASS
Data	4.8	PASS
Additional requirements for software controlled short-circuit isolators	4.9	NA
Reproducibility	5.2	PASS
Variation in supply voltage	5.3	PASS
Dry heat (operational)	5.4	PASS
Cold (operational)	5.5	PASS
Damp heat, cyclic (operational)	5.6	PASS
Damp heat, steady state (endurance)	5.7	PASS
Sulphur dioxide (SO ₂) corrosion (endurance)	5.8	PASS
Shock (operational)	5.9	PASS
Impact (operational)	5.10	PASS
Vibration, sinusoidal (operational)	5.11	PASS
Vibration, sinusoidal (endurance)	5.12	PASS
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

CERTIFICADO DE CONSTANCIA DE LAS PRESTACIONES

Organismo Notificado N° 0370

No. **0370-CPR-1277**

En cumplimiento con el Reglamento (UE) No.305/2011 del Parlamento Europeo y del Consejo de 9 de marzo de 2011 (Reglamento de Productos de Construcción o CPR), este certificado aplica al producto de construcción:

SISTEMAS DE DETECCIÓN Y ALARMA DE INCENDIOS. AISLADORES DE CORTOCIRCUITO.

MODELO: **KZ715I. KILSEN**

Puesto en el mercado por:

CARRIER FIRE & SECURITY B.V.

KELVINSTRAAT, 7
6003 DH WEERT (NETHERLANDS)

Y fabricado en la planta de producción:

CARRIER SAFETY SYSTEM (HEBEI) CO., LTD.

No. 80 CHANGJIANG EAST ROAD, QETDZ, QINHUANGDAO, HEBEI, CHINA 066004

Este certificado acredita que se han aplicado todas las disposiciones relativas a la evaluación y verificación de la constancia de las prestaciones descritas en el Anexo ZA de la norma:

EN 54-17:2005; EN 54-17:2005/AC:2007

bajo el sistema 1, y que el control de producción en fábrica realizado por el fabricante se evalúa para garantizar la constancia de las prestaciones del producto de construcción.

Este certificado fue emitido por primera vez el 23 de marzo de 2012 y su validez permanece mientras no se modifique significativamente la norma armonizada, el producto de construcción, los métodos de EVCP ni las condiciones de fabricación en la planta, a menos que sean suspendidos o retirados por el organismo de certificación de productos notificado. A fecha 5 de agosto de 2022 se confirma éste y todas sus modificaciones anteriores.

El seguimiento se realizará antes de 31 de julio de 2023

Bellaterra, 5 de agosto de 2022


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



Este documento carece de validez sin su anexo técnico, cuyo número coincide con el del certificado.

Puede comprobarse la validez de este certificado en nuestra página web: www.appluslaboratories.com/certified_products

El fabricante, después de completar el procedimiento de evaluación de la conformidad y la declaración de prestaciones, puede colocar el marcado CE bajo su responsabilidad



0370-CPR-1277

Anexo según **EN 54-17:2005; EN 54-17:2005/AC:2007**

SISTEMAS DE DETECCIÓN Y ALARMA DE INCENDIOS. PARTE 17: AISLADORES DE CORTOCIRCUITO

CARACTERÍSTICAS ESENCIALES	CAPÍTULO Y APARTADOS EN ESTA NORMA EUROPEA	NIVELES Y/O CLASES MANDATADAS
Cumplimiento	4.1	PASA
Indicación integral del estado	4.2	PASA
Conexión de los dispositivos auxiliares	4.3	PASA
Monitorización de los aisladores de cortocircuito desmontables	4.4	NA
Ajustes del fabricante	4.5	PASA
Ajustes en el sitio	4.6	NA
Marcado	4.7	PASA
Datos	4.8	PASA
Requisitos adicionales para los aisladores de cortocircuito controlados por software	4.9	NA
Reproducibilidad	5.2	PASA
Variación en la tensión de suministro	5.3	PASA
Calor seco (operacional)	5.4	PASA
Frio (operacional)	5.5	PASA
Calor húmedo cíclico (operacional)	5.6	PASA
Calor húmedo, estado estacionario (resistencia)	5.7	PASA
Corrosión por Dióxido de Azufre	5.8	PASA
Choque(operacional)	5.9	PASA
Impacto	5.10	PASA
Vibración, Sinusoidal (operacional)	5.11	PASA
Vibración, Sinusoidal (resistencia)	5.12	PASA
EMC (inmunidad)	5.13	PASA

PASA; PND = Prestación No Determinada, NA = No Aplica