



EVPU[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0873

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Conventional fire alarm wireless expander module Natron WE-C, SensoIRIS WE-C, WL FIRE WE-C

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC,
Iliyansko Shose Str., NPZ Voenna Rampa 2, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC,
Iliyansko Shose Str., NPZ Voenna Rampa 2, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-18: 2005
EN 54-18: 2005/AC: 2007
EN 54-25: 2008
EN 54-25: 2008/AC: 2012


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on September 25th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, September 25th, 2023

054622



Michal Mišiak

Annex to Certificate 1293 - CPR – 0873 from September 25th, 2023

General Information:

Natron WE-C (and derived variants) is a conventional wireless expander module designed for operation with conventional fire alarm panels, including MAG series panel, produces by Teletek Electronics JSC. Product is powered from external power supply with back-up battery. The module is equipped with special inputs for monitoring the main and back-up power supplies.

Technical specifications:

External power supply	24 VDC
Radio frequency	868MHz
Dimensions	191x125x60mm
Enclosure box type, color	ABS, RAL 7024 (graphite grey)
Weight (with mounted PCB and antenna)	~200g

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005, EN 54-18:2005/ AC:2007	EN 54-25:2008 EN 54-25:2008/ AC:2012	
Performance parameters under fire conditions	cl.5.1.4	cl. 4.1, 4.2.2, 5.2, 8.3.7	Pass
Response delay (response time)	cl. 5.2	8.2.3, 8.2.6	Pass
Operational reliability	cl.5.1.4	cl. 4.2.1, 4.2.3 to 4.2.7, 5.3=N/A, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7 to 8.2.9, 8.3.1, 8.3.2, 8.3.4 to 8.3.5=N/A, 8.3.6	Pass
Durability of operational reliability: temperature resistance	cl. 5.3, 5.4	cl. 8.3.9 to 8.3.10=N/A, 8.3.11	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	cl. 8.3.16=N/A, 8.3.17 to 8.3.19	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	cl. 8.3.12=N/A, 8.3.13, 8.3.14	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	cl. 8.3.15=N/A	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	cl. 8.3.20	Pass



Nová Dubnica, September 25th, 2023

Michal Mišiak
Michal Mišiak