



EVPU®

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0850 Rev.2

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of March 9th, 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

**Intelligent analogue addressable sounder with base
SensolRIS CSOU, Belinda CSOU, Erida CSOU, Marl CSOU,
Smoke sense CSOU, MAGPRO-DBS1**

For specifications see Annex No. 1 and No. 2 to this certificate

placed on the market under the name or trade mark of

**Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC,
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006


under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on July 19th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, July 19th, 2024




Michal Mišiak
Head of CB NB No. 1293

056167

EVPU a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1 / 3 F COCV 7.7.12 Rev.1

Annex No. 1 to Certificate No. 1293 - CPR – 0850 Rev.2 from July 19th, 2024

Technical specifications

SensolRIS CSOU (and derived variants Belinda CSOU, Erida CSOU, Marl CSOU, Smoke sense CSOU, MAGPRO -DBS1) is an addressable sounder with base, compatible for mounting on all models and standard bases for SensolRIS devices. The sounder is designed for installing in addressable fire alarm systems which support operation via TTE communication protocol. The device is powered on from the panel and can be controlled via the communication protocol.

The sounder supports 32 different tone types at two sound levels. The tone type and sound level are programmed from the control panel.

The sounder is compatible for operation with SensolRIS addressable detectors series:

T110 (IS), S130 (IS) and M140 (IS).

The sounder is compatible for mounting on the following bases:

1. SensolRIS B124 - Standard low profile base for addressable detectors and sounders.
2. SensolRIS B124-HP - Standard high profile base for addressable detectors and sounders.
3. SensolRIS VAD RST* - Standard base with built-in red LED flash beacons.
4. SensolRIS VAD WST* - Standard base with built-in white LED flash beacons.

* The base SensolRIS VAD RST/WST is specially designed for use with SensolRIS CSOU IS sounders, as expands their application in fire alarm installations providing additional lighting indication in case of fire alarm events.

Products parameters (Part 1)

Operating voltage range	16-32V DC
Maximal consumption at communication	470 μ A @ 27VDC
Maximal consumption	
- main tone type 27, low volume level	3mA@ 27VDC
-main tone type 27, high volume level	10 mA @ 27 VDC
Power volume (main tone type 27)	
-low volume(up to 100 pcs sounders* to the loop)	~81dB(A) \pm 3dB@ 1m
-high volume (up to 30 pcs sounders* to the loop)	~88dB(A) \pm 3dB@ 1m
Power volume (other tone type)	
-low volume(up to 100 pcs sounders* to the loop)	~81dB(A) \pm 3dB@ 1m
-high volume (up to 30 pcs sounders* to the loop)	~87dB(A) \pm 3dB@ 1m
Tone type specification	
Tone type 1	970 Hz
Tone type 2	800Hz/970Hz@2Hz
Tone type 3	800Hz - 970Hz@ 1Hz
Tone type 4	970Hz 1s OFF/1s ON
Tone type 5	970Hz 0,5s / 630 Hz, 0,5 s
Tone type 6	554 Hz, 0.1s /440 Hz, 0.4 s (AFNOR NF S 32 001)
Tone type 7	500 – 1200 Hz, 3.5s / 0.5s OFF (NEN 2575:2000)
Tone type 8	420 Hz 0.625s ON/0.625 OFF (Australia AS1670 Alert tone)
Tone type 9	500-1200Hz, 0.5s/0.5s OFF x 3/1.5s OFF (AS 1670 Evacuation)
Tone type 10	550 Hz /440 Hz@ 0.5 Hz
Tone type 11	970 Hz, 0.5s ON / 0.5s OFFx 3/1.5s OFF (ISO 8201)
Tone type 12	2850 Hz, 0.5s ON/ 0.5s OFF x 3/1.5s OFF (ISO8201)
Tone type 13	1200 Hz – 500 Hz @ 1 Hz (DIN 33 404)
Tone type 14	400 Hz
Tone type 15	550 Hz, 0.7 s / 1000 Hz, 0.33 s
Tone type 16	1500 Hz - 2700 Hz @ 3 Hz
Tone type 17	750 Hz
Tone type 18	2400 Hz
Tone type 19	660 Hz
Tone type 20	660 Hz 1.8 s ON / 1.8 s OFF
Tone type 21	660 Hz 0.15 s ON / 0.15 s OFF
Tone type 22	510 Hz 0.25 s / 610 Hz 0.25s
Tone type 23	800/1000 Hz 0.5s each (1 Hz)

Nová Dubnica, July 19th, 2024



Michal Mišiak
Head of CB NB No. 1293

Annex No. 2 to Certificate No. 1293 - CPR – 0850 Rev.2 from July 19th, 2024

Products parameters (Part 1)

Tone type 24	250 Hz – 1200 Hz @ 12 Hz
Tone type 25	500 Hz – 1200 Hz @ 0.33 Hz
Tone type 26	2400 Hz – 2900 Hz @ 9 Hz
Tone type 27	2400 Hz – 2900 Hz @ 3 Hz
Tone type 28	800 Hz – 970 Hz @ 100 Hz
Tone type 29	800 Hz – 970 Hz @ 9 Hz
Tone type 30	800 Hz – 970 Hz @ 3 Hz
Tone type 31	800 Hz 0.25s ON / 1 s OFF
Tone type 32	600 Hz – 1100 Hz, 2.6s / 0.4s OFF
Relative humidity resistance	(93±3)%@+40°C
Color	white
Sounder type	A
Material	ABS
Dimensions	φ 105mm x 22mm
Weight	~ 120 g

Essential characteristics	Harmonised technical specifications	Performance
	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1 to C.5.3=N/A	Pass
Operational reliability	cl. 4.4 to 4.6, 5.4, C.4=N/A	Pass
Durability of operational reliability: temperature resistance	cl. 5.5, 5.6=N/A, 5.7 to 5.9	Pass
Durability of operational reliability: humidity resistance	cl. 5.8, 5.9, 5.10=N/A	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	Pass
Durability of operational reliability: electrical stability	cl. 5.16	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0850	Original certificate issued	December 2 nd , 2022
2	1293-CPR-0850 Rev.1	New location of the company	November 6 th , 2023
3	1293-CPR-0850 Rev.2	Editorial correction	July 19 th , 2024

Nová Dubnica, July 19th, 2024



Michal Mišiak
Head of CB NB No. 1293

056168

