

## DECLARATION OF CONFORMITY

*We,* **Teletek Electronics JSC**  
*Address:* 14A, Srebarna Str.  
1407 Sofia, Bulgaria

*Declares that the*

*Product:* **SensoIRIS MCP150**  
*Description:* Addressable fire alarm manual call point

*Complies to the following standards:*

**EN 54-11:2001/A1:2005**  
**EN 54-17:2005**  
**EN 55032:2015**  
**EN 50130-4:2011/A1:2014**

*The following Regulation:*

**CPR № 305/2011**  
**REACH № 1907/2006**

*And the following Directives:*

**2014/30/EC – EMC**  
**2011/65/EU – RoHS II**

**Additional information:**

*First date of production:* 11.2011

*Certificate:*

№ 1139f/01 of February 29, 2016 from Notified body № 0832 LPCB  
№ 1293- CPR-0473 Rev.1 of August 07, 2017 from Notified body № 1293 EVPU

*Test report:*

№ E123437-1000 of February 29, 2016 from Notified body № 0832 LPCB  
№ C08/14/0026/4206/CA Rev.1 of August 07, 2017 from Notified body № 1293 EVPU

1407 Sofia,  
14A, Srebarna Str.  
30.08.2017

Yuliy Iliev  
Quality Manager

