

## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 14A, Srebarna Str.  
1407 Sofia, Bulgaria

**Declares that the**

**Product:** SensoIRIS MCP150 IP67  
**Description:** Intelligent analogue addressable fire alarm manual call point with built-in isolator module

**Complies with the following standard:**

EN 54-11:2001/A1:2005  
EN 54-17:2005/AC:2007  
IEC 60529:1989 + A1:1999 + A2: 2013  
EN 55032:2015  
EN 50130-4:2011+A1:2014

**The following Regulation:**

CPR № 305/2011  
REACH No 1907/2006

**And the following Directives:**

2014/30/EC- EMC  
2011/65/EU – RoHS II

**Additional information:**

**First date of production:** 11.2016

**Certificate:**

№1293-CPR-0538 Rev.1 of August 07, 2017 from Notified body № 1293 EVPU  
№ 00005/101/1/2017 of February 08, 2017 from Notified body № 1293 EVPU

**Test report:**

№ C08/16/0026/4206/CA Rev.1 of August 07, 2017 from Notified body № 1293 EVPU

1407 Sofia,  
14A, Srebarna Str.  
30.08.2017

Yuliy Iliev  
Quality Manager

