



DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: **SensoIRIS WSST IS**
Description: Intelligent analogue addressable fire alarm sounder with built-in isolator module

Complies to the following standards:

EN 55032:2015
EN 50130-4:2011/A1:2014
EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006
EN 54-17:2005/AC:2007
EN 54-23:2010

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU – EMC
2011/65/EU – RoHS

Additional information:

First date of production: 11.2013

Certificate:

№1293–CPR-0462 Rev.3 of July 19th, 2024 from Notified body № 1293 EVPU
№1139d/01 of September 22th, 2023 from Notified body № 2831 LPCB

Test report:

№ 00511/2014/C of January 29th, 2015 from Notified body № 1293 EVPU
№ TE-E123439-1000 of October 13th, 2016 from Notified body № 2831 LPCB

Note: Sounder Belinda WSST IS is compatible with fire bases SensoIRIS B124 and SensoIRIS WSB IP65

2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
02.08.2024

Yuliy Iliev
Quality Manager



1293