



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0641 Rev.2

In compliance with the *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Conventional Fire Alarm Fixed Temperature Detector
SensoMAG F10, SensoMAG F10B, Precise F10B, Herald F10A,
RunwayLeo F10, SensoMAG F10A Relay, SensoMAG F10B Relay, Eagle F10**

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria
and produced in the manufacturing plant

Teletek Electronics JSC
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-5: 2017+A1: 2018

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 6th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, November 6th, 2023

Michal Mišiak

054841

Annex to Certificate No. 1293 - CPR – 0641 Rev.2 from November 6th, 2023

General information:

The detector SensoMAG F10 and derived variants are compatible with any conventional Fire Panel with fire alarm threshold between 10mA and 15mA (between 10mA and 30mA with B24RD fire base).

The detector can be used with 4 base types:

- B12L/U - Base with relay output (not covered by EN54-5)
- B24 - Standard base; low profile, B24-HP – Standard base, high profile
- B24D - Standard base with Schottky diode
- B24RD - Standard base with Schottky diode and increased alarm state current

Technical specifications

Operating voltage range	9 - 30 V DC (Nom. 12/24VDC)
Class (in accordance with EN 54-5)	A2/S (SensoMAG F10, Herald F10A, RunwayLeo F10, SensoMAG F10A Relay, Eagle F10) B/S (SensoMAG F10B, Precise F10B, SensoMAG F10B Relay)
Dimensions	Φ 102mm h 42mm*, Φ 103mm h 56mm**
Weight (incl. base)	160g*, 170g**

*B12L/U, B24, B24D, B24RD

**B24-HP

Essential characteristics	Harmonised technical specification	Performance
	EN 54-5: 2017 + A1: 2018	
Operational reliability	cl. 4.2.1, 4.2.2, 4.2.3=N/A, 4.2.4, 4.2.5, 4.2.6=N/A, 4.2.7	Pass
Nominal activation conditions / Sensitivity	cl. 4.3.1 to 4.3.6	Pass
Response delay (response time)	cl. 4.4.1, 4.4.2=N/A	Pass
Tolerance to supply voltage	cl. 4.5.1	Pass
Durability of Nominal activation condition / Sensitivity: Temperature resistance	cl. 4.6.1.1, 4.6.1.2=N/A	Pass
Durability of Nominal activation condition / Sensitivity: Humidity resistance	cl. 4.6.2.1, 4.6.2.2	Pass
Durability of Nominal activation condition / Sensitivity: Corrosion resistance	cl. 4.6.3	Pass
Durability of Nominal activation condition / Sensitivity: Vibration resistance	cl. 4.6.4.1 to 4.6.4.4	Pass
Durability of Nominal activation condition / Sensitivity: Electrical stability	cl. 4.6.5	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1.	1293-CPD-0117	Original certificate issued	March 20 th , 2009
2.	1293-CPR-0544	CPR certificate issued	April 11 th , 2017
3.	1293-CPR-0641	Added new variants	March 19 th , 2019
4.	1293-CPR-0641 Rev.1	Testing according to the new edition of standard and new class, added new variants	August 31 st , 2022
5.	1293-CPR-0641 Rev.2	New location of the company	November 6 th , 2023

Nová Dubnica, November 6th, 2023



Michal Mišiak