

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F4498

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

AS363 Conventional Type A Sounder (Red)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

UTC Fire & Security B.V.
Kelvinstraat 7
NL-6003 DH
Weert
The Netherlands

and produced in the manufacturing plant(s):

Texecom Ltd
Bradwood Court
St Crispin Way
Haslingden
Lancashire BB4 4PW
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 10 July 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 10 July 2020

Date of Issue: 10 July 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4498

AS363 Conventional Type A Sounder (Red)

Bases:

PSO-0001 – Shallow base – Red (Type A)

Sounder Tones:

- 1 – Continuous 970 Hz
- 2 – Alternating 800-970 @ 2 Hz
- 3 – Sweep 800-970 @ 1 Hz
- 6 – Alternating 554 Hz, 0.1s / 44 Hz, 0.4s
- 7 – Sweep 500-1200 Hz, 3.5s / Off, 0.5s
- 13 – Sweep 1200-500 Hz @ 1 Hz

P. Halligan

P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 10 July 2020

Date of issue: 10 July 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie