

## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 2, Iliyansko shose str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria

**Declares that the**

**Product:** iRIS4

**Description:** Expandable addressable Fire Alarm Control Panel

**Complies with the following standards:**

EN 54-2:1997  
EN 54-2:1997/AC:1999  
EN 54-2:1997/A1:2006  
EN 54-4:1997  
EN 54-4:1997/AC:1999  
EN 54-4:1997/A1:2002  
EN 54-4:1997/A2:2006  
EN 62368-1:2014  
EN 55032:2015  
EN 61000-3-2:2006  
EN 61000-3-3:2013

**The following Regulation:**

CPR № 305/2011  
REACH No 1907/2006

**And the following Directives:**

2014/30/EU- EMC  
2014/35/EU- LVD  
2011/65/EU- RoHS II

**Additional information:**

**First date of production:** 26.09.2023

**Certificate:**

№ 1293 – CPR - 0866 of September 25<sup>th</sup>, 2023 from Notified body № 1293 EVPÚ a.s.

**Test report:**

№ 0-01-01E/23 of April 26, 2023 from SNAS Reg. No. 010/S-042  
№ 9-0013/23 of April 26, 2023 from SNAS Reg. No. 010/S-042  
№ 9-0013S/23 of April 26, 2023 from SNAS Reg. No. 010/S-042

2, Iliyansko shose str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria  
26.09.2023

Yuliy Iliev  
Quality Manager



**1293**

