



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0868

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

**Wireless fire alarm manual call point
Natron MCP-PR, Natron MCP-PB, SensoIRIS MCP-PR,
SensoIRIS MCP-PB, WL FIRE MCP-PR, WL FIRE MCP-PB**

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

**Teletek Electronics JSC,
Iliyansko Shose Str., NPZ Voenna Rampa 2, 1220 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC,
Iliyansko Shose Str., NPZ Voenna Rampa 2, 1220 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-11:2001
EN 54-11:2001/A1:2005
EN 54-25:2008
EN 54-25:2008/AC:2012**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on September 25th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, September 25th, 2023

054617




Michal Mišiak

Annex to Certificate 1293 - CPR – 0868 from September 25th, 2023

General Information:


Natron MCP (and derived variants) is a wireless addressable manual call point designed for operation with Natron series wireless expander modules. The fire alarm condition can be activated by breaking the glass and then pressing the button. The status LED on the front panel starts blinking fast.

To reset the call point back to standby mode, it is necessary to open the front cover (door) using a special key and replace the broken glass with a new one. The call point is resetting automatically with closing the front cover (door).

Technical specifications:

Battery power supply	1 x CR123A 3V
Radio frequency	868MHz
Type	B
Dimensions	125x125x36mm
Enclosure box type	ABS
Color	RAL 3020 (red)
Weight (with battery)	~200g
Mounting	Wall, Indoor use

Essential characteristics	Harmonised technical specification		Performance
	EN 54-11:2001 EN 54-11:2001/A1:2005	EN 54-25:2008 EN 54-25:2008/AC:2012	
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl.4.3.2, 4.4, 4.7.1, 4.7.4=N/A, 5.2, 5.3	cl. 4.1, 4.2.2, 5.2, 8.3.7	Pass
Response delay (response time)	-	8.2.3, 8.2.6	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	cl. 4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7 to 8.2.9, 8.3.1, 8.3.2, 8.3.4 to 8.3.6	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8=N/A, 5.9	cl. 8.3.9 to 8.3.11	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	cl. 8.3.16 to 8.3.19	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11=N/A, 5.12, 5.19=N/A	cl. 8.3.12 to 8.3.14	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11=N/A, 5.13	cl. 8.3.15	Pass
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	cl. 8.3.20	Pass



Michal Mišiak

Nová Dubnica, September 25th, 2023