



Certificate of Continued Compliance 142290011/AA/05



Issued 07-05-2024 Replaces 142290011/AA/04
Expiry date 07-05-2028 Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: 12V dc Switch Mode PSU (13.8V) 1.5A in C box
Trademark: ARITECH
Type designation: PM812N-G3
Serial No: N/A
Hardware / Software: 02B / 01B

Placed on the market under the name or trademark of:

Name of the manufacturer: Carrier Fire & Security B.V.
Address: Kelvinstraat 7
City: 6003DH Weert
Country: Netherlands

This certificate is granted to:

Name of the certificate holder: Carrier Fire & Security B.V.
Address: Kelvinstraat 7
City: 6003DH Weert
Country: Netherlands

Ron Scheepers
Managing director

This certificate has THREE Annexes.

CERTIFICATE

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Security Grade: 3

Environmental Class: II

Equipment class: Fixed

Power supply type: A

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

Elmdene International Ltd.

Keel Close 3

Portsmouth

United Kingdom

Product inspection location:

Carrier Fire & Security B.V.

Kelvinstraat 7

Weert

Netherlands

The product as described in this certificate includes the following type designations

- Product description: 12V dc Switch Mode PSU (13.8V) 1.5A in C box
- Trademark: ARITECH
- Type designation: PM812N-G3
- Hardware version: 02B
- Software version: 01B
- Serial number: N/A