

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: SensoIRIS T110 IS
Description: Analogue addressable fire alarm heat detector with built-in isolator module

Complies to the following standards:

EN 54-5:2017; EN 54-5:2017/A1:2018
EN 54-17:2005; EN 54-17:2005/AC:2007
EN 55032:2015
EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC
2011/65/EU- RoHS II

Additional information:

First date of production: 08.2011

Certificate:

№ 1293-CPR-0453-Rev.2 of November 6th, 2023 from Notified body № 1293 EVPU

Test Report:

№ C08/21/0026/4203, 4206/SL-6 of April 27, 2022 from Notified body № 1293 EVPU

Note: To be used in conjunction with base B124.

2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
08.12.2023

Yuliy Iliiev
Quality Manager

