



Certificate of Conformity

Product Certification Scheme 5

Certificate No. 31235-01-23-INT

This certificate applies to the products
**Wireless Door Contact, Wireless 2-Zone Door Contact
& 8 Zone Expansion Module**

with name and/or type designation
DCT6 (433/868 MHz), DCTXP2 (433/868 MHz) and ZX82

Placed on the market by
**Paradox Security Systems (Bahamas) Ltd.
6 Milton Street, Freeport, Grand Bahama 5
Bahamas**

Produced in the manufacturing plant by
**Paradox Security Systems Ltd
780 Industrial Boulevard St. Eustache, QC J7R 5V3 Canada**

This certificate attests that all provisions concerning the assessment and the performance described in the standards

EN 50131-2-6

EN 50131-3

are applied and that the products fulfil all the prescribed requirements

This Certificate is valid until 2027-02-03

Høvik, Norway 2023-02-03
For Applica Test & Certification AS

A handwritten signature in blue ink, appearing to read 'Jan Rune Pedersen'.

Jan Rune Pedersen, Certification Manager



Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Certificate History		
Revision	Description	Issue Date
–	Initial Issue	2023-02-03

Products Covered by this Certificate		
Product Name	Product Description	Applied Standards
DCT6 (433/868 MHz)	Wireless Door Contact	EN 50131-2-6:2008 EN 50131-1:2006+A1:2009+A2:2017/A3:2020
DCTXP2 (433/868 MHz)	Wireless 2-Zone Door Contact	EN 50131-6:2017 EN 50130-4:2011+A1:2014 EN 50130-5:2011
ZX82	8 Zone Expansion Module	EN 50131-3:2009 EN 50131-1:2006+A1:2009+A2:2017/A3:2020 EN 50130-4:2011+A1:2014 EN 50130-5:2011

Application/Limitation

- Security Grade 2 for DCT6 and DCTXP2
- The security Grade of ZX82 is depending on the security grade of the system where it is installed. The maximum-security grade is 3.
- Environmental Class II for all three products
- Control Panel shall be certified to EN 50131-6 and used as the power supply for the expansion module. If an external power supply is used, it must be certified for EN 50131-6.
- Suitable for indoor application

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Documents Reviewed	
Document ID	Description
PARIAS_EN 50131-2-6.30676	EN 50131-2-6:2008
PARIAS_EN 50131-2-6.31049	EN 50131-1:2006+A1:2009+A2:2017
PARIAS_EN 50131-3.30676	EN 50131-1:2006+A1:2009+A2:2017 EN 50131-3:2009
bis-rec-1441-01_Paradox_Wireless Magnetic Contacts DCT6 _Class II for SO2 test	EN 50131-2-6:2008 EN 50130-5:2011
bis-rec-1441-00_Paradox_Wireless Magnetic Contacts DCT6 - DCTXP2 _Class II for SO2 test	EN 50131-3:2009 EN 50131-2-6:2008 EN 50130-5:2011
PARENV_EN.30676	EN 50130-5:2011
PARENV_EN.31387	
PAREMC_30220_31168	EN 50130-4:2011+A1:2014
PAREMC_31049	
PARIAS_EN 50131-6.31840	EN 50131-6:2017
PARIAS_EN 50131-6.31049	EN 50131-1:2006+A1:2009+A2:2017
PARIAS_EN 50131-6_TypeC.30676	EN 50131-1:2006+A1:2009+A2:2017 EN 50131-6:2008
LFT-EMEA-UK-OP-24h	FPC Audit report

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The products listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Significant changes in the manufacturing plant
- Changes in the test methods and/or factory production control requirements included in the standards, used to assess the performance of the declared characteristics

END OF CERTIFICATE